

Operating Ireland's power system at high non-synchronous renewable generation levels


WinGrid Workshop, 18 June 2021

simon.tweed@eirgrid.com



Presentation Overview

- To provide an insight into how EirGrid and SONI operate the power system of Ireland and Northern Ireland today with high levels of wind and how this will evolve in the future.



<http://www.eirgridgroup.com/how-the-grid-works/system-information/>

System Overview

Peak Demand: 6878 MW

Installed Wind: 5600 MW

Peak Wind: 4437 MW

Installed Solar: 120 MW


Peak Solar: 112 MW



Moyle
+/- 500 MW
HVDC (LCC)
to GB

EWIC
+/- 500 MW
HVDC (VSC)
to GB


Installed Wind Capacity (MW)






Operations Today

Forecasts



Scheduling and Dispatch



Constraint - SNSP

SNSP is an operational metric that is used to represent the amount of non-synchronous generation, such as Wind or Solar Generation, on the system at an instant in time. It is the ratio of the real-time MW contribution from non-synchronous generation and net HVDC interconnector imports to demand plus net HVDC interconnector exports. The equation to express SNSP as a percentage is thus formulated as follows:

$$SNSP(\%) = \frac{\text{Non-synchronous generation} + \text{net interconnector imports}}{\text{Demand} + \text{net interconnector exports}} \times 100$$

Current limit is 70 % (trialling 75% from April 2021)

Constraint - Inertia

Inertia is an operational metric that represents the amount of kinetic energy stored in the rotating masses of generators. The power system's inertia determines the sensitivity of the system frequency towards supply demand imbalances. The higher the power system's inertia, the less sensitive is the frequency to temporary imbalances.

Current floor is 23,000 MWs

Constraint - RoCoF




RoCoF (or Rate of Change of Frequency) is an operational metric that represents the rate at which the system frequency changes in the timeframe immediately following a system event which disconnects a generator or load from the system.

$$RoCoF = \frac{\text{System frequency} \times \text{Active Power}_{lost}}{2(\text{Inertia}_{system} - \text{Inertia}_{lost})}$$



Where: Active Power_{lost} = Output of Generator in MW which was disconnected from the System, Inertia_{system} = Total System Inertia being provided as stored kinetic energy by all rotating masses, including generation, on the System and Inertia_{lost} = Inertia being provided by the Generator which was disconnected from the System.

Current limit is 0.5 Hz/s (trailing 1.0 Hz/s limit from June 2020)

Constraint – Ramping Requirements



Scheduling and Dispatch



Windfarm Real-Time Controls

MW Setpoint

Frequency Response On/Off

Frequency Deadband
200mHz/15mHz

Reactive Power Control Mode
(V, Q, PF)

Reactive Power Setpoint



Constraint and Curtailment
management

Frequency Response

Reactive Power / Voltage
Support

Windfarm Services

From
Wind?





Service Name	Abbreviation	Unit of Payment	Short Description
Synchronous Inertial Response	SIR	MWs ² h	(Stored kinetic energy)*(SIR Factor – 15)
Fast Frequency Response	FFR	MWh	MW delivered between 2 and 10 seconds
Primary Operating Reserve	POR	MWh	MW delivered between 5 and 15 seconds
Secondary Operating Reserve	SOR	MWh	MW delivered between 15 to 90 seconds
Tertiary Operating Reserve 1	TOR1	MWh	MW delivered between 90 seconds to 5 minutes
Tertiary Operating Reserve 2	TOR2	MWh	MW delivered between 5 minutes to 20 minutes
Replacement Reserve – Synchronised	RRS	MWh	MW delivered between 20 minutes to 1 hour
Replacement Reserve – Desynchronised	RRD	MWh	MW delivered between 20 minutes to 1 hour
Ramping Margin 1	RM1	MWh	The increased MW output that can be delivered with a good degree of certainty for the given time horizon.
Ramping Margin 3	RM3	MWh	
Ramping Margin 8	RM8	MWh	
Fast Post Fault Active Power Recovery	FPFAPR	MWh	Active power (MW) >90% within 250 ms of voltage >90%
Steady State Reactive Power	SSRP	Mvarh	(Mvar capability)*(% of capacity that Mvar capability is achievable)
Dynamic Reactive Response	DRR	MWh	MVAr capability during large (>30%) voltage dips

* Capable but currently not a contracted service

Wind Constraint Groups

Thermal / Voltage Constraints



Tools

Wind Dispatch Tool

Dispatch Methodology: Band Order: Pro Rata: Manual: Min: 0 Max: 147 Delta: 48 Actual Gen (MW): 148

Dispatch Target: 100 Target Limit: 200

Dispatch Functions: Total DMOL for Dispatch: 19 Disable DMOL:

Calculate Setpoints Reason for Dispatch: TRANSMISSIONCONSTRAI Issue Setpoints

Failed to Achieve Units: 1 Failed to Achieve MW: 25 Achievement Tracking

Dispatch Availability: Total Availability: 148 Total MW Range: 148

Breakdown Functions: Apply Regional Break Down Apply Band Order Break Down Apply Wind Farm Break Down

Selected For Dispatch	Windfarm Name	Region	Constraint Group	Curtail Selected	Curtail Setpoint MW	Curtail [Y/N]	Constrain Selected	Constrain Setpoint MW	Constrained [Y/N]	Category	Constraint Band Priority	AP/EA Status	Permissible Capacity	Available MW	Actual MW	Last SetPoint Issued	Set Point Feedback	Last SP Successful	Freq Rps to send	Freq Rps Status
<input checked="" type="checkbox"/>	BEAMHILL_PL1	DONEGAL	DONEGAL	<input type="checkbox"/>	14.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2.2	<input type="checkbox"/>	1	OFF	14.0	13.0	13.9	14.0	14.0	OK	Rem. ON	ON	
<input checked="" type="checkbox"/>	CRKMORE_PL1	DONEGAL	DONEGAL	<input type="checkbox"/>	10.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1.6	<input type="checkbox"/>	1	OFF	10.0	8.8	9.9	10.0	10.0	OK	Rem. ON	OFF	
<input checked="" type="checkbox"/>	FLUGLAND_PL1	DONEGAL	DONEGAL	<input type="checkbox"/>	9.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1.4	<input type="checkbox"/>	1	OFF	9.2	8.0	9.1	9.2	9.2	OK	Rem. ON	ON	
<input checked="" type="checkbox"/>	LDERYUJ_PL1	DONEGAL	DONEGAL	<input type="checkbox"/>	8.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0.0	<input type="checkbox"/>	1	OFF	8.0	7.0	7.9	8.0	8.0	OK	Rem. ON	OFF	
<input checked="" type="checkbox"/>	MENACULIN_PL1	DONEGAL	DONEGAL	<input type="checkbox"/>	12.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0.0	<input type="checkbox"/>	1	OFF	12.0	10.8	11.9	12.0	12.0	OK	Rem. ON	OFF	

Configuration Tools: RT-LA System Scenario & Data Display & Tools Study Tools PSAT Study VSAT Study TSAT Study

RT LA LAST CYCLE

Study ID: D08_14-28+08-32 Completed: 14:11:00 Elapsed: 00:04:42 Status: **Pass**

Contingency Analysis Results For 09/08/20 19:00:00 - 08/09/18

Basecase

RT	10:00v	10:00v	12:00v	13:00v	14:00v
VSA: SECURE	VSA: SECURE	VSA: SECURE	VSA: SECURE	VSA: SECURE	VSA: SECURE
TSA: SECURE	TSA: SECURE	TSA: SECURE	TSA: SECURE	TSA: SECURE	TSA: SECURE

No Insecure Contingencies

Transfer Analysis Results For 09/08/20 19:00:00 - 08/09/18

Clark v Great Island

Base: 793.6 Limits: 1033.6 Limiting Reason: AD_32RA_INF0R

VSA: 1033.6 Collapse Dispatch Overload Voltage SPS 794 1099 1224

EWIC_export

Base: 500.0 Limits: 1500.0 Limiting Reason: Insufficient Dispatchable Reserve

VSA: 1500.0 Collapse Dispatch Overload Voltage SPS 500 1025 1550

Wind Inp. by 450 MW

Base: 258.1 Limits: 708.1 Limiting Reason:

VSA: 708.1 Collapse Dispatch Voltage SPS 258 483 708

Load Inp. by 400 MW

Base: 4669.2 Limits: 5069.2 Limiting Reason:

VSA: 5069.2 Collapse Dispatch Voltage SPS 4669 4669 5069



Display Limit **Print** Cases

Look Ahead Stability Assessment Tool




Where we are today

- In April 2021 we raised the SNSP limit to 70% and we are now currently trialling operation up to 75%.



February 2021

System Non-Synchronous Penetration % (SNSP)





Future Operations

Policy Drivers



- + 10 GW of RES (onshore/offshore wind and solar)
- 700k heat pumps and 1m electric vehicles
- c. 1.7 GW of additional Large Energy User demand
- New transmission network and HVDC interconnection

2030 Operational Challenges


Significant technical challenges will emerge if no action is taken

1. FREQUENCY STABILITY AND CONTROL



- Inertia
- Reserve
- Ramping
- Very low Frequency Oscillations

2. CONGESTION



- Lack of Transmission Capacity

3. TRANSIENT STABILITY



- Reduction in Synchronising Torque
- Reduction in Damping Torque

4. POWER QUALITY



- Harmonics

5. OTHER



- Voltage Dip Induced Frequency Deviation
- Frequency Regulation
- Power System Protection
- Power System Modelling
- Forecasting

CURTAILMENT



Curtailment due to overall power system limitations

6. VOLTAGE STABILITY



- Steady-State Voltage Control
- Dynamic Voltage Control
- Reduction in Available Fault Current

7. SYSTEM RESTORATION




- Less Black-Start Capable Plant

8. GENERATION ADEQUACY



- Capacity Margin
- Weather-Related Events

70% RES-E requires operating in a new way



- Inertia levels are below today's minimum allowed level of 23,000 MW.s for ~ 70% of time.
- RoCoF levels are above today's maximum allowed level of 0.5 Hz/s for ~ 85% of time.
- SNSP levels are above today's maximum allowed level of 70% for ~ 60% of time.
- Number of large units online is below today's minimum allowed level of 8 for ~80% of time

★ Limit today ★ Limit used in TES modelling to satisfy 70% RES-E

Operational Transition

